

Commissioning tester for PV system up to 1500V / 40A







DRAFT Rel. 1.00xC - 13/04/23

Commissioning tester up to 1,500V and 40A

Page 1 of 5

PVCHECKs-PRO is a one-stop test solution to meet the IEC 62446-1 standards for category 1 tests.

PVCHECKs-PRO performs on single-face (SF) as well as on bifacial (BF) photovoltaic systems all tests required by the IEC 62446-1 to commission a photovoltaic installation **in automatic sequence**. Therefore, **by a single GO-key stroke** PVCHECKs-PRO measures and tests:

- continuity of protective earthing and/or equipotential bonding conductors, where fitted;
- polarity test;
- string open-circuit voltage test up to 1500V;
- string short-circuit current test **up to 40A**;
- insulation resistance of the DC circuits by generating up to 1500V even on live circuits.

As required by IEC 62446-1, **PVCHECKs-PRO** compares the just-measured values of string Voc and Isc to the previously measured strings composing the PV installation to prevent voltage and current mismatching.

By measuring the solar radiation (SOLAR03 required) and PV module temperature, PVCHECKs-PRO can extrapolate Voc and Isc to the STC (Standard Test Conditions: 1000W/m², 25°C, AM 1.5) to compare them to the nominal values as provided by the module manufacturer. The internal database already stores the most popular modules, more modules can be added. Finally, PVCHECKs-PRO provides a positive or negative outcome (OK/NO).

Insulation resistance of DC circuits is performed according to IEC 62446-1 test method 1. Two tests are then performed: a first test between array negative and earth followed by a second test between array positive and earth, avoiding the use of any short-circuit switch box (*).

Troubleshooting is a time consuming and costly activity. Any time an inverter shuts down because of lack of insulation, the quickest it is recovered it to normal operation, the quickest the installation returns to generating power and income. GFL is the new function **PVCHECKs-PRO** performs answering each technician's question: where is the fault? By this function **PVCHECKs-PRO** indicates the precise position of the lack of insulation, so the technician can go without fail to service the broken component

(*) According to IEC 62446-1, insulation resistance test method 2 would require the use of a short-circuit switch box (incorporating a load break rated DC switch) to safely make and break the short circuit connection - after array cables have been safely connected into the device.




Tel: +39-0546-621002 - Fax: +39-0546-621144 email: export@ht-instruments.com

web: http://www.ht-instruments.com

HT ITALIA SRLVia della Boaria 40 - 48018 Faenza (RA)- Italy







Commissioning tester up to 1,500V and 40A

Page 2 of 5

1. GENERAL FEATURES

Feature		Note
Ratings		CAT III 1500VDC
PV module type - all most common types of photovoltaic module	Single face	✓
	Bifacial	✓
Voltage range		15V – 1500V DC
Current range		0.1A – 40A DC
DMM (input voltages)		✓
Wireless environmental parameters measurement (free field; max	Irradiance	✓
100m, bluetooth connection with SOLAR03 required)	Module temperature	✓
Commissioning tests @ OPC (OPerating Conditions)	Open circuit voltage (Voc)	✓
	Short circuit current (Isc)	✓
Commissioning tests @ STC (Standard Test Conditions) (free field;	Open circuit voltage (Voc)	✓
max 100m, bluetooth connection with SOLAR03 required)	Short circuit current (Isc)	✓
Performance/Acceptance tests @ OPC (OPerating Conditions) – Voc a	and Isc:	✓
Performance/Acceptance tests @ STC (Standard Test Conditions)	Voc and Isc	✓
(free field; max 100m, bluetooth connection with SOLAR03 required)	Outcome (OK/NO)	✓
Continuity of protective earthing and/or equipotential bonding conducto	✓	
Insulation measurement	Module	✓
(DUAL mode and TIMER mode with test voltage 250V, 500V, 1000V, 1500V)	Array/string	✓
	✓	
GFL (Ground Fault Locator)	✓	
PV module datasheet data base		60 internal 150000 on PC
Memory		999 Test
Data transfer / Communication port	USB and WiFi	
Graphic LCD	240 x 240 pxl	
Help on line	✓	
Buzzer		✓
Batteries	6 x 1.5V alkaline AA	✓
	6 x1.2V rechargeable AA	✓
Temperature range		-10°C – +50°C
Waterproof		IP40



Tel: +39-0546-621002 - Fax: +39-0546-621144 email: export@ht-instruments.com

web: http://www.ht-instruments.com

HT ITALIA SRL Via della Boaria 40 - 48018 Faenza (RA)- Italy



Commissioning tester up to 1,500V and 40A

Page 3 of 5

2. ELECTRICAL SPECIFICATIONS

Accuracy is calculated as \pm [% readings + (no. of digits) * resolution] at 23 °C \pm 5 °C, relative humidity <80%HR

2.1. DMM

DC Voltage		
Range (V)	Resolution (V)	Uncertainty
3 ÷ 1500	1	\pm (1.0%rdg + 2dgt)

AC TRMS Voltage		
Range (V)	Resolution (V)	Uncertainty
3 ÷ 1000	1	± (1.0%rdg + 3dgt)

Frequency range: 42.5 ÷ 69Hz; Voltages zeroed for measured value <3V

2.2. FUNCTIONAL TEST

IV CHECK - DC Voltage @ OPC			
Range (V)	Resolution (V)	Uncertainty	
3.0 ÷ 1500.0	0.1	±(1.0%rdg + 2dgt)	
Minimum VPN voltage to start the test: 15V			

IV CHECK - DC Current @ OPC		
Range (A)	Resolution (A)	Uncertainty
0.10 ÷ 40.00	0.01	±(1.0%rdg + 2dgt)
PV module stray capacitance: max 30uF		

IV CHECK - DC Voltage @ STC				
Range (V)	Resolution (V)	Uncertainty		
3.0 ÷ 1500.0	0.1	$\pm (4.0\% \text{rdg} + 2 \text{dgt})$		

IV CHECK - DC Current @ ST	rc .	
Range (A)	Resolution (A)	Uncertainty
0.10 ÷ 40.00	0.01	±(4.0%rdg + 2dgt)

GFL (Ground Fault Locator)				
Test voltage DC [V]	Range [MΩ]	Resolution [M Ω]	Accuracy (*)	Position accuracy
	$0.1 \div 0.99$	0.01		
250, 500, 1000, 1500	1.0 ÷ 19.9	0.1	\pm (5%rdg + 5dgt)	± 1module
	20 ÷ 100	1		

Open voltage <1.25 x nominal test voltageShort circuit current <15mA (peak) for each test voltage Nominal measured current >1mA on R = $1\text{k}\Omega$ x Vnom (with VPE, VNE= 0)

(*) For Accuracy the following constraints shall be considered:

Accuracy is indicated for VPN ≥240V, Rfault≥10Ω

Accuracy for Rp and R(+) is not declared if R(+) \geq 0.2M Ω and R(-) < 0.2M Ω Accuracy for Rp and R(-) is not declared if R(+) < 0.2M Ω and R(-) \geq 0.2M Ω

Set limit threshold on measure $0.05M\Omega$, $0.1M\Omega$, $0.23M\Omega$; Number of set modules: $4 \div 35$

The GFL function allows obtaining correct results under the following conditions:

- ➤ Test carried out with Vtest ≥Vnom on a <u>single ungrounded string</u> disconnected from the inverter and from possible arresters
- > Test performed upstream of any blocking diode
- ightharpoonup Single fault of low insulation located at any position across the string
- > Insulation resistance of the single fault <0.23MΩ
- > Environmental conditions similar to those in which the fault was reported

จัดจำหน่ายโดย : บริษัท เอฟเวอร์เทด จำกัด TEL : (02)8702884-5, (02)4289793-5 Email: sales@evertech.co.th www.evertech.co.th

Tel: +39-0546-621002 - Fax: +39-0546-621144 email: export@ht-instruments.com web: http://www.ht-instruments.com

HT ITALIA SRL

Via della Boaria 40 - 48018 Faenza (RA)- Italy



DRAFT Rel. 1.00xC - 13/04/23

Commissioning tester up to 1,500V and 40A

Page 4 of 5

2.3. SAFETY TEST

Continuity Test (RPE)		
Range [Ω]	Resolution [Ω]	Uncertainty
$0.00 \div 9.99$	0.01	
10.0 ÷ 99.9	0.1	\pm (2.0%rdg+2dgt)
100 ÷ 1999	1	

Test current >200mA DC up to 2Ω (test leads included), Resolution 1mA, Test current uncertainty $\pm (5.0 \text{wrdg} + 5 \text{dgt})$

Open loop voltage $4 < V_0 < 10V$

Insulation Test (M Ω) – Mode TIMER			
Test voltage [V]	Range [M Ω]	Resolution [M Ω]	Uncertainty
250 500 1000 1500	$0.01 \div 9.99$	0.01	1/5 00/ rda . Edat)
250, 500, 1000, 1500	10.0 ÷ 99.9	0.1	\pm (5.0%rdg+ 5dgt)

Open voltage: < 1.25 * nominal test voltage
Short circuit current: <15mA (peak) for all test voltages

Generated voltage Resolution 1V, uncertainty ±(5.0%rdg + 5dgt) @ Rmis> 0.5% FS

Test current > 1 mA with load = $1 \text{k}\Omega \times \text{Vnom}$

Insulation Test (M Ω) – Mode DUAL			
Test voltage DC [V]	Range [MΩ]	Resolution [M Ω]	Accuracy (*)
	0.1 ÷ 0.99	0.01	
250, 500, 1000, 1500	1.0 ÷ 19.9	0.1	\pm (5.0%reading + 5digits)
	20 ÷ 100	1	

 $\begin{array}{ll} \mbox{Open voltage} & < 1.25 \ x \ nominal \ test \ voltage \\ \mbox{Short circuit current} & < 15 mA \ (peak) \ for \ each \ test \ voltage \\ \mbox{Nominal measured current} & > 1 mA \ on \ R = 1 k\Omega \ x \ Vnom \ (with \ VPE, \ VNE=0) \\ \end{array}$

(*) For Accuracy the following constraints shall be considered:

Accuracy is indicated for VPN ≥240V, Rfault≥10Ω

Accuracy for Rp and R(+) is not declared if R(+) \geq 0.2M Ω and R(-) <0.2M Ω Accuracy for Rp and R(-) is not declared if R(+) < 0.2M Ω and R(-) \geq 0.2M Ω



Tel: +39-0546-621002 - Fax: +39-0546-621144 email: export@ht-instruments.com

email: export@ht-instruments.com web: http://www.ht-instruments.com



DRAFT Rel. 1.00xC - 13/04/23

Commissioning tester up to 1,500V and 40A

Page 5 of 5

3. GENERAL SPECIFICATIONS

DISPLAY AND MEMORY:

Features: graphic COG LCD 240x240 with backlight

Memory: max 999 test, 3 levels of marker

Internal Data Base of PV module: 60

POWER SUPPLY:

Internal: 6x1.5V type AA alkaline or

6x1.2V type AA NiMH rechargeable battery

External battery charger for NiMH batteries is required

Battery life: RPE: > 500 Test (RPE ≥ 0.10hm)

GFL, M Ω : > 500 Test (Riso \geq 1k Ω x VTest, 5sec on, 25s off) IVCK: > 500 Test (no SOLAR03, see a.m. conditions for RPE, M Ω)

OUTPUT INTERFACE

PC communication: USB and WiFi

SOLAR-03 communication: BT communication (max distance 100m – outdoor free field)

MECHANICAL FEATURES

Dimensions (L x W x H): 225 x 165 x 75mm; (9 x 6 x 3in)

Weight (batteries included): 1.2kg; (42 ounces)

Mechanical protection: IP40

ENVIRONMENTAL CONDITIONS:

Reference temperature: $23^{\circ}\text{C} \pm 5^{\circ}\text{C}$; $(73^{\circ}\text{F} \pm 41^{\circ}\text{F})$ Operating temperature: $-10^{\circ}\text{C} \div 50^{\circ}\text{C}$; $(14^{\circ}\text{F} \div 122^{\circ}\text{F})$

Allowable relative humidity: <80%RH

Storage temperature: $-20^{\circ}\text{C} \div 60^{\circ}\text{C}$; $(-4^{\circ}\text{F} \div 140^{\circ}\text{F})$

Storage humidity: <80%RH Max. operating altitude: 2000m (6562ft)

GENERAL REFERENCE STANDARDS:

Safety: IEC/EN61010-1, IEC/EN61010-2-034

EMC: IEC/EN61326-1 Safety of measurement accessories: IEC/EN61010-031

Measurements: IEC 60891, IEC/EN62446-1 (IVCK)

IEC/EN 61557-1, 2, -4 (RPE, MΩ)

Technical documentation: IEC EN 61187 Insulation: double insulation

Pollution degree: 2

Overvoltage category: CAT III 1500V to ground, Max 1500VDC, 1000V~ between inputs

Max. operating altitude: 2000m (6562ft)

This instrument satisfies the requirements of Directives:

RED: Directive 2014/53/EU, LVD: Directive 2014/35/EU, EMCD: Directive 2014/30/EU

RoHS: Directive 2011/65/EU, WEEE: Directive 2012/19/EU

งัดจำหน่ายโดย : บริษัท เอฟเวอร์เทด จำกัด TEL : (02)8702884-5, (02)4289793-5 Email: sales@evertech.co.th www.evertech.co.th

Tel: +39-0546-621002 - Fax: +39-0546-621144

email: export@ht-instruments.com web: http://www.ht-instruments.com